

FORT BELVOIR
Paint Shop
Inspection Checklist

Facility _____ Area _____
Inspector _____ Date _____

	Yes	No
1. Is the paint shop in a specially constructed and isolated fire-resistant room or building?	___	___
2. Have personnel been specifically instructed in hazards encountered in painting?	___	___
3. Are floors, equipment, and other exposed surfaces kept clean?	___	___
4. Is the ventilation provided adequate to remove flammable and injurious substances from the atmosphere?	___	___
5. Do personnel wear proper respirators while spray painting?	___	___
6. Are precautions taken to ensure that there is no clogging, leaking, or rupturing of the hose lines?	___	___
7. Is the air pressure checked frequently to see that it is within a safe limit?	___	___
8. Are hand-operated stop valves installed in strategic points so that fixed pipes may be shut off quickly?	___	___
9. Are booths provided with ample sprinkler heads, which are inspected and cleaned frequently?	___	___
10. Have all sources of ignition in the vicinity of paint operations been eliminated?	___	___
11. Are all motors, fixtures, switches, and other electrical devices of an approved explosion-proof type?	___	___
12. Is smoking expressly prohibited?	___	___
13. Are all exhaust ducts boned and grounded and are the exhaust fans of nonferrous metal?	___	___
14. Are the right types and sizes of fire extinguishers provided where spray painting is being done?	___	___

